

INTERIOR MASS NOTIFICATION MESSAGES - EGLIN AFB

Department of Defense, Unified Facilities Criteria 4-021-01

Sept 2017

Authorization for MNS to temporarily override Fire Alarm audible messages and visual signals for providing intelligible voice commands during simultaneous fire and terrorist events (Priority is electronic override of above message – example: 1, 2, & 3 will override 4)

Priority	Type	Pre-Tone	Message Script (Tones and Messages Repeat a Minimum of Three Times)
1	Local Live Voice	None	LOCAL, IN-BUILDING P.A.: Special Announcement for All or Zones in Facility.
2	Bomb Threat	Continuous	May I have your attention please! A bomb threat has been reported in or around this Building 0000. Please follow the pre-plan and await further instructions.
3	Intruder	Continuous	May I have your attention please! An intruder or hostile person has been sighted within or around this Building 0000. Please follow the pre-plan and await further instructions.
4	Alternate Exit	Continuous	May I have your attention please! Please evacuate Building 0000 – using pre-designated Alternate Exits.
5	FIRE	Code 3	May I have your attention please! A FIRE emergency has been reported in this Building 0000. Please depart to your nearest Exit and report to your designated Assembly Area.
6	Shelter In-Place	Continuous	May I have your attention please! Please shelter in-place and await further instructions.
7	Weather	None	May I have your attention please! The National Weather Service has issued a severe weather warning for our area. Please await further instructions.
8	All Clear	None	May I have your attention please! This Building emergency has ended. An “All Clear” has been given. Please resume normal activities.
9	TEST	None	May I have your attention please! This is a TEST of the Mass Notification System. This is only a TEST.

- 1** *Emergency Notification System ONLY; NOT to be utilized for Non-Emergency Messaging Traffic.*
- 2** *Mass Notification System is a Life Safety application authorized only for real-time intelligible voice communications of an actual emergency situation with instructions to personnel for response and action.*
- 3** *Relay #4, linked to priority #6, FIRE, shall not be activated remotely.*