

March 3, 2022

ADDENDUM NUMBER 1

F22-068 HEERF B86 Tech Infrastructure Projects

All respondents must acknowledge receipt of this Addendum by signing in the space provided below. **Return signed addendum with submittals.**

The following are the questions we received by the deadline established in the referenced projects above:

Q & A: Building 86:

Q1: Please provide a contact for the fire alarm vendor unless there will be an allowance for fire alarm work included with a future addendum?

A1: Contact info for fire alarm vendor is:

Siemens
David Stewart
stewart.david@siemens.com

Q2: Where can I find the Appendix 1 per Page 8 of 315 in the specs which states C. Minimum Insurance Coverages and Requirements per Appendix 1?

A2: Article 6, Section C (page 8 of 315) should read: C. *For Minimum Insurance Requirements reference UWF Vendors Guide available on UWF Procurement website:* <http://uwf.edu/offices/procurement/vendors-only/vendors-guide/>.

- [Minimum Insurance Requirements for Major Construction](#)
- [Minimum Insurance Requirements for Minor Construction](#)

Q3: RFI 01: Please provide current Davis Bacon Wage Rates that apply to this project. None were provided in the specifications for Building 18 or Building 86.

A3: Please see the [Federally Funded Projects Amendment section](#) on Davis-Bacon Act that reads the following: **Davis-Bacon Act, as amended (40 U.S.C. 276a to a-7) (projects in excess of \$2,000.00)** – If required by the Federal program legislation, Vendor covenants and agrees that all laborers and mechanics employed by Vendor and its subcontractors on this project will be paid in compliance with the Davis-Bacon Act (40 U.S.C. 276a to a-7) and as supplemented by Department of Labor regulations (29 CFR part 5, "Labor Standards Provisions Applicable to Contracts Governing Federally Financed and Assisted

Construction"). Under this Act, Vendor is required to pay wages to laborers and mechanics at a rate not less than the minimum wages specified in a wage determination made by the Secretary of Labor. In addition, Vendor is required to pay wages not less than once a week.

Q4: Building 86: Drawing A501 door schedule indicates the new door to be Hollow Metal. Specification section 081416 indicates a wood door. Drawing A-114 indicates a wood door. Is the door hollow metal or wood? Please clarify.

A4: *Provide a wood door for door 109.*

--

For reference, the other two doors in the door schedule and their associated hardware can be reused and will be reinstalled in new frames. Door 109 to the new comm room has a different swing and different hardware than existing, is why we only have just one new door.

Q5: Building 86: The specifications manual includes a PLUMBING section with the following specifications but there are no plumbing drawings and nothing is shown on the M series drawings. Are there any plumbing requirements?

220000 PLUMBING GENERAL
220010 CODES AND STANDARDS
220523 VALVES
220529 HANGERS AND SUPPORTS
220539 TESTING, CLEANING AND STERILIZATION
220553 PLUMBING IDENTIFICATION
220719 PLUMBING PIPING INSULATION
221116 DOMESTIC WATER PIPING

A5: The Plumbing work entails relocation of two small (approximately 3/4") domestic water (hot and cold water) pipes outside of the footprint of 109 COMM as noted by Sheet Note 3/M-101. The new domestic water routing is indicated on Sheet M-111 and shall match existing size and piping material and shall be insulated, as noted by Sheet Note 4/M-111.

Q6: In the specifications, page 287 under 2.5 B2 it calls for ST connectors. On the next page, 288, both MM and SM fiber patch cords are SC. Please clarify

A6: Provide per the Specification Section 271300.2.5.B.2

Q7: Specifications page 287, 2.5 A manufacturers referenced are Ortronics, Panduit, and CommScope and on page 288 #8 references Manufacturer: Superior Modular Fiber LIU. Please clarify.

A7: Provide per the Specification Section 271300.2.5.A

Q8: Are splice cassettes acceptable method of fiber optic termination in the Fiber LIU?

A8: No objections to utilizing cassettes in the Fiber LIU.

Q9: Are splice connectors acceptable method of fiber optic termination?

A9: Provide per the Construction Documents and Specifications.

All other criteria and information contained in this solicitation remain the same and without change.

FAILURE TO SIGN BELOW AND RETURN WITH RESPONSE MAY RESULT IN RESPONSE BEING DISQUALIFIED.

Respectfully,

Brittany Bezick-Hamel
Senior Buyer, Procurement & Contracts
University of West Florida
850.474.2627
bbezickhamel@uwf.edu

RESPONDENT'S SIGNATURE

NAME OF RESPONDENT FIRM