


- LEGEND:**
- SOIL OR WASTE PIPING
 - T — TRAP PRIME PIPING
 - GW — GREASE WASTE PIPING
 - A — COMPRESSED AIR PIPING
 - OWS — OIL WATER SEPARATOR
 - SP — SUMP PUMP
 - FD — FLOOR DRAIN
 - AC — AIR COMPRESSOR
 - RAD — REFRIGERATED AIR DRYER
 - VTR — VENT THRU ROOF
 - GW — GREASE WASTE
 - AD — AIR DROP
 - CO — CLEANOUT
 - PW — POWER WASHER



PUMP SCHEDULE - BASIS OF DESIGN

MARK	SERVICE	TYPE	SIZE	PERFORMANCE DATA		ELECTRICAL DATA			REMARKS	
				CAPACITY MAX GPM	MAX HEAD FT. (H ₂ O)	MAXIMUM MOTOR - H.P.	VOLTS	PHASE		HERTZ
SP-1	WASHDOWN AREA	SUMP	6"	370	92	6.2	--	--	--	7 kw motor W/VFD TO ADJUST FLOW
PUMP-1	INSPECTION AREA	SLUDGE	4"	100	55	1/2	115	1	60	W/VFD TO ADJUST FLOW

NOTES:
PUMP SHALL BE UL508 AND 778 APPROVED.
PUMP TO BE PROVIDED WITH MECHANICAL SEAL.