

SOLICITATION W50S6Y-25-B-A004 Combine Weapons Fac- LSGA239001

Addendum 02 Q&A

Date of Bid Inquiry: 2/28/2025

Questions 4:

Ref. CU101 & T-601, Keynote 33.82.14: Please clarify the location of the existing Telecomm vault, new Telecomm manhole and new Telecomm duct bank and clearly show them on Utility Layout Plan CU101.

AE.

Date of response: 3/6/2025

By: Brian McNuckle

Response:

- **Existing Telecomm Vault:** The existing telecommunications vault MH-8 is located at the corner of Saber Ave and Shooting Star Road, which is outside the project limits.
- **New Manhole Installation:** Install a new manhole (MH) within the project limits, connecting to the existing BTE duct bank.
- **New Telecomm Duct:** Install a new telecommunications duct from the new manhole (MH) to the telecommunications room. Splice and extend in new manhole (MH) as required to install and terminate in new telecom room.

Please refer to the revised drawing CU101.

See below for revision:

