



Goodwyn Mills Cawood

720 Bayfront Parkway
Suite 200
Pensacola, FL 32502

T (850) 432-0706
F (448) 216-0241

www.gmcnetwork.com

Goodwyn Mills Cawood, LLC
Kelly Wieczorek
Qualifying Agent
FL Architect AR96359

FRICKER RESOURCE CENTER RENOVATION

Revision 04

Date: 06-19-2026

GMC # APEN250016

SUMMARY OF REVISIONS

Drawings

CIVIL

1. Sheet C4.0
 - a. Cut-In lateral connection to existing sewer main on De Soto Street shifted approximately 47 LF east
 - b. 2. 4" sewer lateral extended to both west and south to reach plumbing connection locations provided by W3 Engineering
 - c. 4" sewer lateral total length increased from 29 LF to 300 LF
 - d. Total 4" cleanout count increased from 0 to 8
 - e. Grease trap location shown per plans provided by W3 Engineering
2. Sheet C4.1
 - a. Typical 4" sewer lateral detail added

ARCHITECTURAL

1. Sheet G1.11 – Revised restroom accessories tags
2. Sheet D1.02 – Revised demolition scope of renovation area
3. Sheet A1.03 – Updated New work plan to reflect new scope at renovation area
4. Sheet A1.12 – Updated restroom elevations/enlarged plans
5. Sheet A1.13 – Updated restroom elevations/enlarged plans

STRUCTURAL

No changes issued

MECHANICAL

No changes issued

PLUMBING

1. Sheet P1.11
2. Sheet P1.12
3. Sheet P1.21
4. Sheet P1.22

Building Communities



- 5. Sheet P4.02
- 6. Sheet P4.03
- 7. Sheet P9.01

FIRE PROTECTION

No changes issued

ELECTRICAL

No changes issued

TELECOM

No changes issued

END OF REVISION 04