



Goodwyn Mills Cawood

720 Bayfront Parkway
Suite 200
Pensacola, FL 32502

T (850) 432-0706
F (448) 216-0241

www.gmcnetwork.com

Goodwyn Mills Cawood, LLC
Kelly Wieczorek
Qualifying Agent
FL Architect AR96359

FRICKER RESOURCE CENTER RENOVATION

Revision 05

Date: 08-04-2026

GMC # APEN250016

SUMMARY OF REVISIONS

Drawings

CIVIL

No changes issued

ARCHITECTURAL

1. Sheet A1.03 – Revised New Work Dimension Plan to reflect storm water chases changes clarified on RFI #20: Interior Storm Water Chase Sizes.

STRUCTURAL

1. Sheet S.101 - Revised 16"x16" CMU column detail to utilize 16x16 CMU column blocks (instead of (2) 8x16 CMU). This was to be able to utilize the center core of the column for roof drain pipe.
2. Sheet SD.101 - Revised concrete header to run across new opening due to pour existing steel beam bearing condition at existing wall corner. (previously released as ASI001).

MECHANICAL

No changes issued

PLUMBING

1. Sheet P1.23 – Sanitary Piping New Work Roof Plan – Revised routing of piping for drop off canopy as clarified in RFI #21: Colonnade Columns Encapsulating Storm Risers.

FIRE PROTECTION

No changes issued

ELECTRICAL

No changes issued

Building Communities



TELECOM

No changes issued

END OF REVISION 05