

Addendum Date: April 14, 2026

CITY OF PENSACOLA, FLORIDA
Bid No. 26-029

ADDENDUM #4

**HIGH PERFORMANCE MARINE CENTER OF EXCELLENCE
DOCK COMPLEX**

The following items take precedence over the documents for the item named above. All other terms and conditions shall remain the same.

**A SIGNED COPY OF THIS PAGE MUST BE RETURNED WITH YOUR SUBMITTAL AS
ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM.**

Company: _____ Date: _____

Authorized
Representative: _____ Title: _____
Printed Name

Signature: _____

Some questions were missed in Addendum 3 and are addressed herein.

Questions and Answers

1. Although sheet pile installation is anticipated from the landside, the work remains directly adjacent to navigable waters and is integral to the marine dock structure which will be classified as a USL&H work zone if anyone were to get hurt performing that work. Please confirm if USL&H coverage is required for all sheet pile installation personnel, subcontractors, and equipment operators engaged in this waterfront scope.
As Referenced in Addendum #2 posted on April 8: "The scope of work indicates that all work is anticipated to be performed from a landside perspective; therefore, Marine Liability insurance (which includes USL&H Coverage) is not required. Should a contractor's proposal include work from a waterside perspective, the contractor shall obtain all applicable and appropriate marine-related insurance coverage."
2. Drawing C102 indicates an existing buried electrical line running north to south. Please provide elevations for the lines or confirm that the contractor should assume these lines to be below any require excavation for the area paving.
Vendor should refer to updated drawings in Amendment A3 (drawings).
3. Asking for clarification on whether the reinforcing in the approach slab needs to be epoxy-coated.
Not required. Bidders are encouraged to provide pricing for this in their bid if they desire.